

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 30.5.2025

It is certified that an inspection team headed by D.R. Nirmal Pratap Singh

(Name of Officers with designation) from S.H.C. Phulpur.....PHED

inspected the RPM Public School, Chak Mohammad urf. Puresudi, Phulpur

(Name & Address of the school) on 06.05.2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no..... 44 dated 13.05.2025

of Jal Kal Vibhag, Nagar Nigam (PHED Lab) certified that the RPM Public School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till One year.....

Signature with Seal: 
Name विकल्प अधिकारी
Designation प्रधान सचिव
Name & Address of the Office / Department:

To
RPM Public School
Chak Mohammad urf. Puresudi Phulpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Principal
RPM PUBLIC SCHOOL
Chak Mohammad urf Puresudi
Phulpur, Prayagraj


MANAGER
R.P.M. PUBLIC SCHOOL
Chak Mohammad urf Puresudi
Phulpur, Prayagraj



कार्यालय अधिकारी अभियन्ता (मु०)
जलकल विभाग-नगर निगम प्रयागराज
पत्र सं० ५५ मु०ज०क०लिंग
दिनांक १५/०५/२०२५

JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2025-05/01

Date: 13.05.2025

DRINKING WATER ANALYSIS REPORT

1	Name & Address	RPM PUBLIC SCHOOL, CHAK MOHAMMAD URF PURESUDI, PHULPUR, PRAYAGRAJ-212402		
2	Sample Collected by	By Party		
3	Nature of Sample	Drinking Water(R.O)		
4	Date of Sample Collection	06.05.2025		
5	Date of Sample Receiving	06.05.2025		
6	Date of Analysis Completed	13.05.2025		

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	
3.	Temperature	°C	24.6	-	
4.	Turbidity	NTU	0.6	5	10
5.	Conductivity at 25°C	µmho/cm	488.0	-	

CHEMICAL PARAMETERS

6.	pH	-	6.8	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	NIL	-	-
8.	Dissolved Solids	mg/L	69.0	500	2000
9.	Total Solids	mg/L	69.0	-	
10.	Total Alkalinity (as CaCO ₃)	mg/L	51.0	200	600
11.	Total Hardness (as CaCO ₃)	mg/L	21.0	200	600
12.	Chlorides (as Cl)	mg/L	76.0	250	1000
13.	Fluoride (as F) mg/l	mg/L	NIL	1.0	1.5
14.	Nitrate (as NO ₃)	mg/L	NIL	45.0	100.0
15.	Iron (Fe)	mg/L	NIL	0.3	1.0

BACTERIOLOGICAL PARAMETERS

16.	Total Coliform	MPN/100ml	Absent	Absent	-
17.	E. Coli	MPN/100ml	Absent	Absent	-

*Note: The water is suitable for drinking purposes-

Analyst

(Laboratory In-charge)

JE(HQ)

*अधिकारी (HQ) द्वारा (गुरु
जलकल विभाग
प्रयागराज-प्रदेश)*

Notes on Result
1. The above results are related only to the test performed on the sample.
2. This report is not to be reproduced wholly or in part and can not be used as an evidence in the court of law and
should not be used in any advertising media without our special permission in writing.
3. Sample will be destroyed in the after fifteen days from the date of reporting.
MANAGER
R.P.M. PUBLIC SCHOOL
Chak Mohammad urf Puresudi
Phulpur, Prayagraj

Principal

*RPM PUBLIC SCHOOL
Chak Mohammad urf Puresudi
Phulpur, Prayagraj*



Scanned with OKEN Scanner